

Certificate

EU-Type examination – production type

in accordance with Directive 2014/68/EU

Certificate No.:

01 202 642TR/B-200006

Name and address of the
manufacturer:

Officine Rigamonti S.P.A.
Via Circonvallazione, 9
I-13018 Valduggia (VC)
Italia

It is herewith certified that the type specimen
mentioned below meets the requirements of the
Directive 2014/68/EU.

Tested acc. to Directive
2014/68/EU:

Module B
EU-Type examination – production type

Test report No.:

125790663-20-01 / Revision 3 vom 26.03.2020

Description of type specimen:

Design:

Diaphragm Safety Valve

direct acting, spring loaded Heating-Valves
477

Type/Series:

0477.015.XX = DN 15 (½" x ¾");

0477.020.XX = DN 20 (¾" x 1");

0477.025.XX = DN 25 (1" x 1 ¼");

0477.033.XX = DN 32 (1 ¼" x 1 ½").

Size(s):

Medium/Fluid-Group:

Water and water mixtures from water heating
systems, fluid group 2

Set-Pressure:

0477.DN.27 = 2,5 bar and 0477.DN.32 = 3,0 bar

Production site:

Officine Rigamonti S.P.A.
Via Circonvallazione, 9
I-13018 Valduggia (VC)
Italia

Valid until:

2030-03-26

The CE marking must not be affixed and the Declaration of Conformity not be issued
prior to completion of the corresponding conformity assessment procedure according to
Directive 2014/68/EU.

D-Aachen, 2020-04-06

On behalf Dipl.-Ing. M. Rönning

TÜV Rheinland Industrie Service GmbH
Notified body for pressure equipment, ID-No. 0035
Am Grauen Stein, D-51105 Köln, GERMANY



Regionalbereich Mitte-West
D-54290 Trier, Deworastraße 1-3
Tel +49 651 2005-0, Fax +49 651 2005-126, service-is-mw@de.tuv.com

TÜV-EQ 4137231, E-011-Rev21

Certificate

**EU-Type examination – production type
in accordance with Directive 2014/68/EU**

Certificate No.: **01 202 642TR/B-200011, 1st Amendment**

Name and address of the
manufacturer:

**Officine Rigamonti S.P.A.
Via Circonvallazione, 9
I-13018 Valduggia (VC)
Italia**

It is herewith certified that the type specimen mentioned below
meets the requirements of the Directive 2014/68/EU.

Tested acc. to Directive
2014/68/EU:

Module B – EU-Type examination – production type

Test report No.:

125790663-20-02 / Revision 0, dated 2020-06-18

Description of type specimen:

Diaphragm Safety Valve

Design:

direct acting, spring loaded expansions valves

Type/Series:

0477.015.42 (= 0477 142); 0477.015.52 (= 0477 152); 0477.015.62
(= 0477 162); 0477.015.72 (= 0477 172); 0477.015.82 (= 0477 182);
0477.015.92 (= 0477 192); 0477.015.99 (= 0477 199); 0477.020.42
(= 0477 242); 0477.020.52 (= 0477 252); 0477.020.62 (= 0477 262);
0477.020.72 (= 0477 272); 0477.020.82 (= 0477 282); 0477.020.92
(= 0477 292); 0477.020.99 (= 0477 299); 0477.025.42 (= 0477 342);
0477.025.52 (= 0477 352); 0477.025.62 (= 0477 362); 0477.025.72
(= 0477 372); 0477.025.82 (= 0477 382); 0477.025.92 (= 0477 392);
0477.025.99 (= 0477 399); 0477.033.42 (= 0477 442); 0477.033.52
(= 0477 452); 0477.033.62 (= 0477 462); 0477.033.72 (= 0477 472);
0477.033.82 (= 0477 482); 0477.033.92 (= 0477 492); 0477.033.99
(= 0477 499).

Size(s):

0477.015.XX = DN 15 (½" x ¾"); 0477.020.XX = DN 20 (¾" x 1");
0477.025.XX = DN 25 (1" x 1 ¼"); 0477.033.XX = DN 32 (1 ¼" x 1 ½").

Medium/Fluid-Group:

Cold water supply of water heaters, fluid group 2

Set-Pressure:

0477.DN.42 = 4,0 bar; 0477.DN.52 = 5,0 bar; 0477.DN.62 = 6,0 bar;
0477.DN.72 = 7,0 bar; 0477.DN.82 = 8,0 bar; 0477.DN.92 = 9,0 bar;
0477.DN.99 = 10,0 bar.

Production site:

Officine Rigamonti S.P.A.
Via Circonvallazione, 9
I-13018 Valduggia (VC)
Italia

Valid until:

2030-06-18

The CE marking must not be affixed and the Declaration of Conformity not be issued prior to
completion of the corresponding conformity assessment procedure according to Directive 2014/68/EU.

D-Trier, 2020-12-22

i.A. Dipl. Ing. (FH) Christof Lentjes

TÜV Rheinland Industrie Service GmbH
Notifizierte Stelle für Druckgeräte, Kennnummer: 0035
Am Grauen Stein, D-51105 Köln, GERMANY

Regionalbereich Mitte-West
D-54290 Trier, Deworastr. 1
Tel +49 651 2005-0, Fax +49 651 2005-126, service-is-mw@de.tuv.com



D-011-Rev21

www.tuv.com

 **TÜVRheinland®**
Precisely Right.